

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7315-1496:152 Page 1 of 1

CATEGORY: Power Unit

LISTEE: Firecom Inc., 39-27 59th Street, Woodside, NY 11377
Contract: Howard Kogen (718) 899-1932

DESIGN: Models FC-003, -4.4, -5.4, -8.0, -010, -015 uninterrupted power supply units; followed by additional letters and/or digit; followed by 00F1. Units are intended for use to provide uninterrupted power for computer system used in central stations or monitoring stations. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as **supplemental** power supply units for use to provide uninterrupted power to computer system used in central stations or monitoring stations. **Not approved** for use in lieu of a **required** secondary power supply for fire protective signaling systems as required per NFPA 72, 1993 Edition because the FC Series does not have the capability to provide the required standby power. As required per NFPA 72, the secondary power supply (under maximum normal load) shall have sufficient capacity to operate a local, central station or proprietary system for 24 hours, or an auxiliary or remote station system for 60 hours; and then, at the end of that period, operate all alarm notification appliances for 5 minutes.

XLF: 7315-1520:100

03-10-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

APRIL 22, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager